



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-07264
Inspection Number: 03064669

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9121 FOX FIRE DR HIGHLANDS RANCH
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 12/20/2013
Inspection Time: 12:00 AM
Inspection Type: Final Plumbing
Inspection Code: 40
Outcome: Approved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No