



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-06689
Inspection Number: 03065751

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5091 HIDDEN POND PL CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 12/31/2013
Inspection Time: 12:00 AM
Inspection Type: Weather Resistive Barrier
Inspection Code: 132
Outcome: Disapproved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No

Comments

Staple 8" O.C. or at the diamonds throughout.