



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-08652

Inspection Number: 03066369

Building Inspection Report

Code Reviewed Under: 2012 IBC

Permit Information

Job Address: 8351 N RAMPART RANGE RD # C103, LITTLETON

Job Type: Building

Description: CM - Tenant Improvement

Scope of Work: New

Inspection Details

Inspection Date: 01/06/2014

Inspection Time: 12:00 AM

Inspection Type: Ceiling Rough Electric

Inspection Code: 68

Outcome: Approved

Inspected By: Rich Edgett

Charge Reinspection Fee: No