



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-02444
Inspection Number: 03067827

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 4374 CHATEAU RIDGE LN CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 01/14/2014
Inspection Time: 12:00 AM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

1- Need Handrail entry steps 4 riser