



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-07417
Inspection Number: 03069323

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 15379 PERIWINKLE CT PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 01/23/2014
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Rick Sugar
Charge Reinspection Fee: No

Comments

Foam all exterior and attic boxes
Terminate bath exhaust fan
Co-smoke req'd 15' of bedroom
Install / bond exterior boxes at back entrance