



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-06689
Inspection Number: 03069790

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5091 HIDDEN POND PL CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 01/28/2014
Inspection Time: 8:36 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Cancelled
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

1) Fire dept approval required
2) Low-volt incomplete
NO INSPECTION