



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-06689
Inspection Number: 03070091

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5091 HIDDEN POND PL CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 01/29/2014
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

1) Canlight clearance to PEX
2) Bond fire sprinkler pipe
3) Empty j-box in mech room ceiling???
#1 Correct & Proceed #s 2 & 3 Will check @ Final