



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-06689
Inspection Number: 03070285

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5091 HIDDEN POND PL CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 01/29/2014
Inspection Time: 3:19 PM
Inspection Type: Rough HVAC
Inspection Code: 27
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No