



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-06695
Inspection Number: 03071808

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5043 VERMILLION DR CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 02/11/2014
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Rich Edgett
Charge Reinspection Fee: No