



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-08235
Inspection Number: 03073878

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5022 BALLARAT LN CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 02/21/2014
Inspection Time: 8:58 AM
Inspection Type: Roof Truss
Inspection Code: 127
Outcome: Cancelled
Inspected By: Rick Chadwick
Charge Reinspection Fee: No