



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglas.co.us](mailto:dcbuilding@douglas.co.us)

Permit Number: 13-06689  
Inspection Number: 03075877

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 5091 HIDDEN POND PL CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Master Plan  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 03/05/2014  
**Inspection Time:** 3:32 PM  
**Inspection Type:** Moisture Barrier  
**Inspection Code:** 53  
**Outcome:** Cancelled  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No