



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-07417
Inspection Number: 03076100

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 15379 PERIWINKLE CT PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 03/06/2014
Inspection Time: 12:00 AM
Inspection Type: Final Grade
Inspection Code: 62
Outcome: Approved
Inspected By: UnassignedDESC
Charge Reinspection Fee: No

Comments

Erik Langman