



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 13-08234
Inspection Number: 03077295

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5023 BALLARAT LN CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 03/13/2014
Inspection Time: 12:00 AM
Inspection Type: Underground Plumbing
Inspection Code: 12
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No