



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 13-07417  
Inspection Number: 03078688

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 15379 PERIWINKLE CT PARKER  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Addition

### Inspection Details

**Inspection Date:** 03/20/2014  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final HVAC  
**Inspection Code:** 39  
**Outcome:** Approved  
**Inspected By:** Jerry Hammerton  
**Charge Reinspection Fee:** No