



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 13-06693  
Inspection Number: 03079630

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 5045 VERMILLION DR CASTLE ROCK  
Job Type: Building  
Description: RS - Stock  
Scope of Work: New

### Inspection Details

Inspection Date: 03/27/2014  
Inspection Time: 12:00 AM  
Inspection Type: Rough Frame  
Inspection Code: 29  
Outcome: Disapproved  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No

### Comments

1)Need Engineer stamped plans that matches what is built.