



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-06693
Inspection Number: 03080046

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5045 VERMILLION DR CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 03/31/2014
Inspection Time: 3:25 PM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No