



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-08235
Inspection Number: 03081594

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5022 BALLARAT LN CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 04/08/2014
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Frpl not wired
- 2) Strap ENT away from frpl vent
- 3) Greatroom floor recept must have listed floor box
- 4) Bond fire sprinkler pipe
- 5) Complete furnace wiring
- 6) Bond telecom panel