



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 13-08234  
Inspection Number: 03082908

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 5023 BALLARAT LN CASTLE ROCK  
Job Type: Building  
Description: RS - Stock  
Scope of Work: New

### Inspection Details

Inspection Date: 04/15/2014  
Inspection Time: 2:54 PM  
Inspection Type: Rough Electric  
Inspection Code: 22  
Outcome: Cancelled  
Inspected By: Henry VanSchaack  
Charge Reinspection Fee: No

### Comments

cancelled on site-incorrectly called in