



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 13-08235  
Inspection Number: 03091585

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 5022 BALLARAT LN CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Stock  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 06/03/2014  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No

### Comments

1) Install intersystem bonding buss  
Correct and Proceed