



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-03421
Inspection Number: 03093063

Building Inspection Report

Permit Information

Job Address: 11500 ROXBOROUGH PARK RD LITTLETON
Job Type: Electrical
Description: Other - Replace Damage Secondary Feeder

Inspection Details

Inspection Date: 06/10/2014
Inspection Time: 12:00 AM
Inspection Type: Electric Trench Partial
Inspection Code: 15
Outcome: Approved
Inspected By: Jim Dorsey
Charge Reinspection Fee: No

Comments

should be state inspection
did look at 400' of 3" pvc at legal depths from vault to xformer