



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-03421
Inspection Number: 03093669

Building Inspection Report

Permit Information

Job Address: 11500 ROXBOROUGH PARK RD LITTLETON
Job Type: Electrical
Description: Other - Replace Damage Secondary Feeder

Inspection Details

Inspection Date: 06/11/2014
Inspection Time: 2:06 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Cancelled
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

Wrong Day