



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-04453
Inspection Number: 03096220

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5049 MCCLURE LN CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 06/23/2014
Inspection Time: 12:00 AM
Inspection Type: Preliminary Defensible Space
Inspection Code: 92
Outcome: Approved
Inspected By: Jill Welle
Charge Reinspection Fee: No