



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-03421  
Inspection Number: 03097661

## Building Inspection Report

### Permit Information

**Job Address:** 11500 ROXBOROUGH PARK RD LITTLETON  
**Job Type:** Electrical  
**Description:** Other - Replace Damage Secondary Feeder

### Inspection Details

**Inspection Date:** 06/27/2014  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No