



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 13-08236
Inspection Number: 03102195

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5024 BALLARAT LN CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 07/22/2014
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Recept by garage stairs not GFCI protected
- 2) Recept required at rear exterior grade level
- 3) Support FA cable at flow switch