



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-04453
Inspection Number: 03115741

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5049 MCCLURE LN CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 09/26/2014
Inspection Time: 12:00 AM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release: Yes
Provider: IREA
Outcome: Approved
Inspected By: Rich Edgett
Charge Reinspection Fee: No