



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-04453  
Inspection Number: 03118523

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 5049 MCCLURE LN CASTLE ROCK  
Job Type: Building  
Description: RS - Master Plan  
Scope of Work: New

### Inspection Details

Inspection Date: 10/10/2014  
Inspection Time: 12:00 AM  
Inspection Type: Drywall  
Inspection Code: 38  
Outcome: Disapproved  
Inspected By: Rick Chadwick  
Charge Reinspection Fee: No

### Comments

NOT READY