



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-08295  
Inspection Number: 03121801

## Building Inspection Report

### Permit Information

**Job Address:** 4118 SERENADE RD CASTLE ROCK  
**Job Type:** Roofing  
**Description:** Composition - Primary Residence

### Inspection Details

**Inspection Date:** 10/24/2014  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Drip Edge  
**Inspection Code:** 58  
**Outcome:** Approved  
**Inspected By:** Kerry Keller  
**Charge Reinspection Fee:** No