



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-04453  
Inspection Number: 03126668

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 5049 MCCLURE LN CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Master Plan  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 11/17/2014  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Building  
**Inspection Code:** 108  
**Outcome:** Disapproved  
**Inspected By:** Clayton Rodeback  
**Charge Reinspection Fee:** No

### Comments

Complete exterior finish.  
Paint exterior pvc.  
Secure water heater vent pipes per manufacturer's specs.