



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-04453
Inspection Number: 03126669

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5049 MCCLURE LN CASTLE ROCK
Job Type: Building
Description: RS - Master Plan
Scope of Work: New

Inspection Details

Inspection Date: 11/17/2014
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Laundry counter receipts loose
 - 2) Mstr closet lisght clearance
 - 3) Mstr bdrm & fam rm receipts inop
 - 4) Plate screws stripped at kit GFCI (2nd to left of sink)
 - 5) Install breaker lock for double oven
 - 6) Front porch lights inop
- Inspection Stopped (1st flr ONLY)