



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-05262
Inspection Number: 03130218

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5048 MCCLURE LN CASTLE ROCK
Job Type: Building
Description: RS - Stock
Scope of Work: New

Inspection Details

Inspection Date: 12/02/2014
Inspection Time: 7:35 AM
Inspection Type: Weather Resistive Barrier
Inspection Code: 132
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No