



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-04929  
Inspection Number: 03130988

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

Job Address: 8896 ASPEN LEAF CT LITTLETON  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 12/04/2014  
Inspection Time: 12:00 AM  
Inspection Type: Roof Truss  
Inspection Code: 127  
Outcome: Approved  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No