



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-14031

Inspection Number: 03143086

Building Inspection Report

Code Reviewed Under: 2012 IBC

Permit Information

Job Address: 8361 N RAMPART RANGE RD # B211, LITTLETON

Job Type: Building

Description: CM - Tenant Improvement

Scope of Work: New

Inspection Details

Inspection Date: 01/28/2015

Inspection Time: 12:00 AM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Approved

Inspected By: Brian Brown

Charge Reinspection Fee: No