

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497

Email: dcbuilding@douglas.co.us

Permit Number: 14-05262

Inspection Number: 03143096

## **Building Inspection Report**

Code Reviewed Under: 2012 IRC

## **Permit Information**

Job Address: 5048 MCCLURE LN CASTLE ROCK

Job Type: Building
Description: RS - Stock
Scope of Work: New

## **Inspection Details**

Inspection Date: 01/28/2015 Inspection Time: 12:00 AM Inspection Type: Rough Frame

Inspection Code: 29
Outcome: Disapproved
Inspected By: Kerry Keller
Charge Reinspection Fee: No

## Comments

1) Need to provide 12" clearance on can lights to plex piping or insulate plex piping

2)missing anchor boltleft side of BSMT door max 8" from opening

call Roung Energy insp.