



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-04929
Inspection Number: 03147036

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 8896 ASPEN LEAF CT LITTLETON
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 02/11/2015
Inspection Time: 12:00 AM
Inspection Type: Moisture Barrier
Inspection Code: 53
Outcome: Disapproved
Inspected By: Brian Brown
Charge Reinspection Fee: No

Comments

res