



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-14030

Inspection Number: 03147909

Building Inspection Report

Code Reviewed Under: 2012 IBC

Permit Information

Job Address: 8361 N RAMPART RANGE RD # B213, LITTLETON

Job Type: Building

Description: CM - Tenant Finish

Scope of Work: New

Inspection Details

Inspection Date: 02/13/2015

Inspection Time: 12:00 AM

Inspection Type: Ceiling Rough Electric

Inspection Code: 68

Outcome: Disapproved

Inspected By: Jim Dorsey

Charge Reinspection Fee: No

Comments

can't have pring in rated wall

cut in boxes in rated wall

comm not installed

support mc impaired concentric in fpb

low volt sheathing not plenum