



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-05265
Inspection Number: 03150206

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5164 LE DUC DR CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 02/25/2015
Inspection Time: 12:00 AM
Inspection Type: Rough Energy Compliance Partial
Inspection Code: 130
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No