



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-05264
Inspection Number: 03150739

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5165 LE DUC DR CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 02/27/2015
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Staple NM below din rm recpet on kit wall
- 2) Nailplate kit corner by pantry
- 3) 6'8" head clearance required at stair sconces
- 4) Nailplate throughout bsmnt
- 5) Strap funace flex
- 6) Connector required at top of furnace flex
- 7) Bond telecom panel
- 8) Recept required at grade level on rear exterior