



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 14-04929
Inspection Number: 03151318

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 8896 ASPEN LEAF CT LITTLETON
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 03/03/2015
Inspection Time: 12:00 AM
Inspection Type: Final Driveway
Inspection Code: 43
Outcome: Disapproved
Inspected By: Carlo Turchiano
Charge Reinspection Fee: No

Comments

Driveway does not fall 2%-4% away from road.
Ditchwork not completed.
Remove driveway and replace to meet requirements.
Must call for inspection.