



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 14-05264  
Inspection Number: 03152168

## Building Inspection Report

Code Reviewed Under: 2012 IRC

### Permit Information

**Job Address:** 5165 LE DUC DR CASTLE ROCK  
**Job Type:** Building  
**Description:** RS - Duplex  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 03/09/2015  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Electric Service Equipment  
**Inspection Code:** 23  
**Meter Release:**  
**Provider:** Xcel  
**Outcome:** Disapproved  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No

### Comments

- 1) Install breakers for furnace and at least one 120V GFCI receptacle
  - 2) NM not permitted to be unprotected inside of furnace
  - 3) Broken flex connector not permitted as a chase nipple for NM in furnace
- NOTE: Ufer below and right of garage panel