



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-05265
Inspection Number: 03152169

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5164 LE DUC DR CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 03/09/2015
Inspection Time: 12:00 AM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release:
Provider: IREA
Outcome: Disapproved
Inspected By: Rich Edgett
Charge Reinspection Fee: No

Comments

- 1) Install breakers for furnace and at least one 120V GFCI receptacle
 - 2) NM not permitted to be unprotected inside of furnace
- NOTE: Ufer below garage panel