



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-05264
Inspection Number: 03152765

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5165 LE DUC DR CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 03/11/2015
Inspection Time: 12:00 AM
Inspection Type: Rough Plumbing
Inspection Code: 28
Outcome: Approved
Inspected By: Kerry Keller
Charge Reinspection Fee: No