



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 14-00418
Inspection Number: 03155677

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 9125 CORRAL LN CASTLE ROCK
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 03/20/2015
Inspection Time: 12:00 AM
Inspection Type: Rough Frame Partial
Inspection Code: 26
Outcome: Approved
Inspected By: Clayton Rodeback
Charge Reinspection Fee: No

Comments

Laundry, bath, and kitchen framing