



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 01-0740
Inspection Number: 00104920

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 854 SWANDYKE DR CASTLE ROCK
Job Type: Building
Description: RS - Basement
Scope of Work: Alteration

Inspection Details

Inspection Date: 05/02/2001
Inspection Time: 12:00 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Troy Meissner
Charge Reinspection Fee: No

Comments

No Comment