



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 14-05265
Inspection Number: 03163328

Building Inspection Report

Code Reviewed Under: 2012 IRC

Permit Information

Job Address: 5164 LE DUC DR CASTLE ROCK
Job Type: Building
Description: RS - Duplex
Scope of Work: New

Inspection Details

Inspection Date: 04/14/2015
Inspection Time: 4:15 PM
Inspection Type: Shower Pan
Inspection Code: 65
Outcome: Cancelled
Inspected By: Kerry Keller
Charge Reinspection Fee: No

Comments

cancelled by Mike