



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 01-3096  
Inspection Number: 00140353

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 1404 SILVERHEELS DR LARKSPUR  
**Job Type:** Building  
**Description:** RS - Residential  
**Scope of Work:** Alteration

### Inspection Details

**Inspection Date:** 11/02/2001  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Approved  
**Inspected By:** Troy Meissner  
**Charge Reinspection Fee:** No