



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 01-3096
Inspection Number: 00140357

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 1404 SILVERHEELS DR LARKSPUR
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/27/2001
Inspection Time: 12:00 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Troy Meissner
Charge Reinspection Fee: No