



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 01-3896  
Inspection Number: 00150434

## Building Inspection Report

Code Reviewed Under:

### Permit Information

Job Address: 12163 S PERRY PARK RD LARKSPUR  
Job Type: Building  
Description: CM - Tenant Finish  
Scope of Work: New

### Inspection Details

Inspection Date: 12/13/2002  
Inspection Time: 12:00 AM  
Inspection Type: Drywall  
Inspection Code: 38  
Outcome: Approved  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No