



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 01-4589
Inspection Number: 00160635

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 960 FOX FARM RD LARKSPUR
Job Type: Building
Description: RS - Residential
Scope of Work: Addition

Inspection Details

Inspection Date: 04/04/2002
Inspection Time: 12:00 AM
Inspection Type: Steel
Inspection Code: 17
Outcome: Approved
Inspected By: unknown
Charge Reinspection Fee: No

Comments

STEEL LETTER [LI NA]