Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 15-11534
Inspection Number: 03181749

Building Inspection Report

Permit Information

Job Address: 7236 PINE HILLS WAY LITTLETON
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 06/25/2015
Inspection Time: 12:00 AM
Inspection Type: Drip Edge
Inspection Code: 58
Outcome: Approved
Inspected By: Robert Nunnelley
Charge Reinspection Fee: No