



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 00-1273
Inspection Number: 00019651

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 5814 CHEETAH CHASE LITTLETON
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 04/18/2000
Inspection Time: 12:00 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Approved
Inspected By: dharris
Charge Reinspection Fee: No